



## LOSS BULLETIN

### EQUIPMENT BREAKDOWN LOSS

Community Centre's Boiler Cracked



#### Risk Solutions

**Loss Bulletin**  
Number 4

**The Boiler Inspection and  
Insurance Company of Canada**

[www.biico.com](http://www.biico.com)

On New Year's day between 5:30 a.m. and 10:30 a.m. a short circuit occurred in an electrical connection box. The failure produced a total shutdown of the boiler's pump and low water cut-off device. When the boiler "dry fired" it overheated, cracking all seven lower end sections.

Attempts to weld the cracked sections proved futile. The boiler had to be replaced with a new model.

#### Loss Details

Nature of Business: Community centre  
Type of Equipment: Cast iron heating boiler  
Age of Equipment: 3 years

Final Loss Settlement Amount:  
Physical damage - \$14,293.48



HSB BI&I