



Recommended practice for electrical preventative maintenance

Equipment care bulletin

HSB Canada, part of Munich Re, is a technology-driven company built on a foundation of specialty insurance, engineering, and technology, all working to drive innovation in a modern world, to keep you ahead of risk.

The HSB Recommended Practice for Electrical Preventive Maintenance is based on prevention of the most common and frequent problems leading to electrical equipment failure. While drawing from several sources, as noted in the standard itself, it addresses four basis points regarding electrical maintenance. Electrical apparatus must be kept **CLEAN**, **COOL**, **DRY**, and **TIGHT**.

CLEAN: Electrical apparatus and equipment rooms should be kept clean and free of excessive dust and dirt accumulations. Obviously, consideration is given to the normal environment for the location and the type of equipment installed. Equipment rooms are not to be used for storage and access should be limited to only authorized operations and maintenance personnel. Proper lighting should be maintained in order to ensure that operations and maintenance can be accomplished correctly and safely.

COOL: Excessive heat buildup in electrical apparatus enclosures and equipment rooms can be detrimental to the equipment. Conductors and apparatus are designed for specific maximum heat loads. Exceeding these maximums will result in improper operation and shortened equipment life expectancy. Equipment rooms should be kept cool to prevent excessive heat buildup. Where installed, cooling fans or blowers on equipment must be properly maintained to provide adequate cooling. As well, ventilation openings in equipment enclosures should be kept clean and free from obstruction. If filters are installed they should be changed or cleaned regularly, as recommended by the manufacturer.

DRY: Persistent exposure to moisture as well as direct contact with water can result in equipment failures or shortened life expectancy. Equipment rooms should be kept dry and the equipment protected from moisture. When evidence of moisture contamination is noted, equipment should be examined for damage and necessary repairs made, and the source of the moisture identified and eliminated.

TIGHT: The most common source of electrical equipment failure is loose connections. The single most important part of any electrical equipment maintenance program is action to ensure all connections are properly maintained and kept tight. Care should be taken to follow any applicable manufacturer's instructions for tightening connections. As effective means of testing for loose connections is infrared imaging. An infrared imaging survey should be a regular part of a comprehensive electrical maintenance program.

As with any standards regarding equipment maintenance, HSB recommends that applicable jurisdictional requirements be followed first, followed next by specific manufacturers' recommendations. As a minimum, HSB recommends that electrical preventive maintenance be performed at three year intervals. More frequent intervals should be followed where conditions warrant. An effective maintenance program is one that can demonstrate that appropriate maintenance is done on a regular and routine basis. Finally, proper maintenance can only be done by qualified and competent maintenance personnel.

Introduction

Electrical equipment failures account for millions of dollars in damage and lost business every year. As this country's electrical infrastructure continues to age, this problem is only going to worsen unless active steps are taken to counter the trend. Ironically, more than two-thirds of electrical system failures can be prevented by a routine preventive maintenance program. Studies show that the failure rate of electrical equipment is three times higher for components that are not part of a scheduled preventive maintenance program as compared with those that are. In addition, a planned Electrical Preventive Maintenance (EPM) program allows the equipment owner to schedule the system outage at a time of their choosing rather than having to correct major problems resulting from an always untimely failure.

The purpose of this standard is to provide the insured with recommended practices and frequencies that would form the core of a regularly scheduled electrical

preventive maintenance program. All work associated with electric power systems and equipment should be performed in accordance with appropriate manufacturers instructions and guidelines and accepted industry practices. In all cases, appropriate safe work practices should be employed for the protection of all involved personnel. Please see the list of referenced standards at the end of this guide.

Frequency of EPM

In general, HSB recommends a minimum frequency of once every three years for conducting regular preventive maintenance on electrical equipment. Where applicable, this standard will note components that require a more frequent EPM program to help ensure reliability and operation.

It is recognized that individual locations may require more frequent maintenance due to the physical environment or operational nature of the equipment. For example, harsh environments where excessive moisture or dust may be present should have a more frequent EPM program. Similarly, equipment that is used intermittently or equipment critical to a key process should be considered for a more frequent program. Sound engineering judgment should be used in determining if more frequent maintenance is appropriate.

Recommended maintenance practices

The following sections are segmented by equipment type. For each component, a recommended minimum practice for preventive maintenance is provided. Where applicable, additional suggested practices are presented for a more thorough EPM Program.

Switchgear

Enclosures

Ensure that all enclosure panels, doors, and structures are well-maintained in accordance with the manufacturer's specifications. During de-energized maintenance, enclosures are to be vacuum cleaned of all loose dirt and debris. Use of compressed air is not recommended since this may cause foreign particles to become embedded in the insulation or damage insulators. Any buildup of dirt or other contaminants that will not come off with vacuuming should be cleaned with lint free rags using cleaning solvents recommended by the manufacturer.

All vents and fan grills are to be cleaned of all dust and/or dirt accumulations. Ensure that ventilation openings are not obstructed. Where seals and/or gaskets are installed, these should be examined and repaired or replaced as necessary. All doors and access panels should be

properly secured during operation. Where heater elements are installed, these should be cleaned, examined for damage and/or deterioration, and tested. Repair or replace heater elements as necessary.

In environments where there is an extreme exposure to adverse conditions, the frequency of maintenance for enclosures should be increased as conditions warrant.

Most types of outdoor high voltage switchgear are provided with moisture /condensation reducing heater modules. Maintenance should include a check that the heater modules are operating satisfactorily.

Electrical equipment rooms or vaults should be kept cleaned of dirt and/or dust accumulations on a regular basis. Doors and windows should be maintained in proper working order and kept closed during routine operation. Access doors should be clearly marked to alert personnel that live electrical equipment is in use. Where ventilation and/or air conditioning are used, all fan motors should be cleaned and examined for signs of wear and deterioration.

Fan blades should be cleaned of dirt and dust and bearings should be properly lubricated. Vent openings should be cleaned of all dust and dirt accumulations. Filters should be cleaned and/or changed as recommended by the manufacturer; or more often if conditions warrant. Electrical equipment rooms should never be used as storage areas.

Electrical equipment rooms or vaults should be examined for evidence of water seepage. The tops of electrical equipment enclosures should be examined for evidence of water since this is a common entryway that often goes undetected until a failure occurs. The source of the water should be

immediately identified and corrective measures taken to permanently correct the condition.

Insulators, supports, and connectors

Inspect insulators and conductor supports for signs of cracking, broken pieces, and other physical damage or deterioration. Clean all loose dirt with lint free rags. For contaminants that will not remove easily, solvents approved by the manufacturer may be used. Examine for evidence of moisture that may lead to tracking or flashover while in operation. Examine surrounding areas for signs of tracking, arcing, or overheating. Repair or replace damaged insulators and supports as necessary.

Examine all bolts and connecting devices for signs of deterioration, corrosion, or overheating. Ensure that bolts and connecting devices are tight, according to manufacturer's specifications. Be careful not to over-torque bolts and connecting devices since insulators are easy to damage and difficult to replace. Where copper and aluminum conductors and/or connectors are used together, examine connections for signs of galvanic action. Ensure that the connectors are properly used and installed in accordance with manufacturer's specifications. Apply an antioxidant compound to all aluminum-to-copper connections.

Conductors

Examine insulation for signs of deterioration, cracking, flaking, or overheating. Examine all connections for signs of overheating, cracked or broken connectors, and signs of tracking or arcing. Ensure that conductors are clean and dry. Examine and clean all connections, and torque to manufacturer's recommendations.



Air circuit breakers

Insulation

Remove and clean interphase barriers. Clean all insulating materials with vacuum and/or clean lint free rags. If it is necessary to use cleaning solvents, use only solvents recommended by the manufacturer. Inspect for signs of corona, tracking, arcing, or thermal or physical damage. Ensure that insulation is left clean and dry.

Contacts

Ensure that all contacts are clean, smooth, and in proper alignment. Ensure that spring pressures are maintained according to manufacturer's specifications. On silver contacts, discoloration is not

Older breakers equipped with carbon contactors generally require very little maintenance. Examine for proper pressure, deterioration, or excessive dressing which may interfere with their proper operation.

Draw-out contacts on the circuit breaker and the stationary contacts in the cubicle should be cleaned and inspected for overheating, alignment, and broken or weak springs. Coat contact surfaces with contact lubricant to ease mating (see manufacturer's recommendations).

Arc interrupters

Clean all ceramic materials of loose dirt and examine for signs of moisture, make sure the assemblies are clean and dry. Examine for cracked or

Operating mechanism

Inspect for loose, broken, worn, or missing parts (consult manufacturer's schematics for required parts). Examine for excessive wear of moving parts. Observe that operating mechanisms function properly without binding, hanging, or without delayed action. Ensure any lubrication is done according to the manufacturer's specifications. Ensure mechanisms are clean, properly lubricated, and all bolts and screws are properly secured. Repair or replace as necessary.

Auxiliary devices

Inspect operating devices for proper operation and general condition. Ensure all indicating devices are fully functional and properly set. Protective relays and circuit breaker trip devices should be inspected and tested according to manufacturers' specifications and applicable industry standards.

Vacuum circuit breakers

All maintenance is similar to that performed on air circuit breakers. As always, it is recommended that the manufacturer be consulted for specific maintenance and testing procedures.

The integrity of the vacuum chamber is often tested by applying a test voltage across the open contacts of the breaker. However, this can be a destructive test and is therefore not recommended by HSB.

Caution: This procedure can produce X-ray emissions, so personnel should maintain a safe distance from the breaker if this test is performed. It is important to closely follow manufacturer's recommended procedures if conducting this test in order to ensure that proper results are obtained. The breaker vapor shield can accumulate an electrostatic charge during this test. Ensure that it is discharged immediately following the test.



usually harmful unless caused by insulating deposits. Clean silver contacts with alcohol or silver cleaner using nonabrasive cloths.

Manually close breaker to check for proper wipe, contact pressure, contact alignment, and to ensure that all contacts make at approximately the same time. If possible, a contact resistance test should be performed to determine the quality of the contacts.

broken pieces. Dirt and arcing deposits may be removed by light sanding – do not use emery cloth or wire brushes which may leave conductive residue behind. Repair or replace as necessary.

Examine arc chutes for dirt and/or duct accumulations and clean as necessary. Dielectric testing of arc shields may be recommended by the manufacturer. Check air puffer for proper operation.

Air disconnect switches

Inspect and clean insulators and conductors as with circuit breakers. Tighten connections in accordance with manufacturer's specifications. Do not over tighten as this may result in damage to connectors.

If cleaning solvents are used, ensure that they are as recommended by the manufacturer. Where abnormal environmental conditions exist, more frequent inspection and cleaning may be required.

Check the operation of the arc blades, if applicable, and ensure proper wipe of the main contacts. Interphase linkages and operating rods should be inspected to make sure that the linkage has not been bent or distorted and that all fastenings are secure. The position of the toggle latch to the switch operating linkage should be observed on all closed switches to verify the switch is mechanically locked in a closed position. Operate switch manually several times to ensure proper operation, and then by motor if power- operated. Ensure that all moving parts are properly secured and lubricated as specified by the manufacturer.

Contact resistance testing of each phase contact should be performed. The results should be recorded and analyzed to ensure proper contact is being made. If the contact resistance of the switch exceeds recommended minimums, repair or replace the switch immediately.

Oil circuit breakers

External

Inspect the enclosure for signs of oil leakage. Clean external bushings assemblies and examine for signs of deterioration, tracking, and loose or broken parts. Observe oil gauge to ensure device is operating properly and measuring the oil level accurately.

Insulating oil test

Conduct a dielectric screen test of the insulating fluid. Based on the results of this test, filter or replace oil as required. Heavy carbon content can indicate potential contact wear and should be investigated further.

Internal

Since the contacts for oil circuit breakers are not readily accessible for inspection, the contact resistance should be tested as a minimum.

More extensive maintenance on the contacts might be require draining the oil and dropping the tank, and is therefore performed less frequently. Follow manufacturer's recommended schedule for examination of internal components such as contact inspections. Open breaker and examine contacts for wear and/or excessive deterioration. Examine linkages for loose, broken, or missing parts; repair or replace as necessary.

Auxiliary devices

Operating mechanisms should be maintained as with air circuit breakers. Where applicable, examine oil level indicators, sight glasses, oil lines, gaskets, and tank lifters for proper conditions. Repair or replace as necessary and in accordance with manufacturer's recommendations.

Examine arc-quenching assemblies for carbon deposits or other contaminants. Follow manufacturer's recommendations for cleaning.

Molded-case circuit breakers

Molded-case circuit breakers should be kept clean for proper ventilation of the breakers. These types of breakers are usually tripped by a thermal element that senses an increase in temperature due to excessive current draw. However, if dirt accumulates on

the surrounding of the breaker, the heat build-up may not be permitted to dissipate properly and result in nuisance tripping.

Clean the breaker housing and inspect it for cracks or signs of overheating. Tighten all connections. Exercise the breaker several times to ensure the mechanism has freedom of movement and to allow contact wiping.

In addition, larger duty circuit breakers (225 amps or above) should be electrically trip tested to ensure proper operation of the trip elements and trip linkages. Refer to the latest edition of the National Electrical Manufacturer's Association (NEMA) Standard AB4, Procedures for Verifying Field Inspections and Performance Verification of Molded-Case Circuit Breakers. If possible, test contact resistance to ensure quality of breaker contacts.

All molded-case circuit breaker panels should be cleaned of all dirt, dust, and debris using a vacuum.

Battery stations / chargers

Batteries

Following should be done **monthly**:

- Thoroughly clean all battery surfaces of dust and/or dirt accumulations. Clean and tighten all terminal connections. Remove any corrosion on battery terminals with bicarbonate of soda.
- Clean battery studs and cable ends. On stranded cable, if ends are corroded, cut off ends or separate strands and clean internally.
- Check electrolyte levels and specific gravity, where applicable. Variations of more than fifty (50) points between cells may indicate a bad cell.

Charger

Following should be done **monthly**:

- Clean all dust and/or dirt accumulations from charger. Clean all vent openings and ensure that they are free from obstructions.
- Check terminals and connections for tightness. Check all relays, lights, and other indicating devices for proper operation.
- If all cells consistently read low, check charger for proper operation. If electrolyte levels are low, check charger rate settings against the manufacturer's specifications. Consistently low levels may indicate the charge rate is too fast.

Capacity tests

In addition to the aforementioned battery inspections, certain tests should be performed to assess whether or not the battery meets the manufacturer's specifications, or whether the battery is performing adequately, or even to determine whether the battery is performing up to the requirements of the system. In general, a performance test of a battery should be conducted within the first two years from the initial installation, and every five years thereafter.

Safety

Caution – While charging, some batteries emit explosive gases. Allow no open flames or sparks permitted near charging batteries. Battery rooms should be well ventilated and smoking should not be permitted.

Cables and Bus

Cables must be de-energized if they are to be touched or moved during maintenance.

Cables in manholes

Caution: Check for dangerous gases using a properly calibrated test meter before entering an confined space such as a manhole.

Inspect for sharp bends, physical damage, excessive tension, oil leaks, pits, cable movement, soft spots, cracked jackets, damaged fireproofing, poor ground connections, deteriorated and corroded or weakened cable supports. Inspect for wear at entrance point and at supports. Inspect manhole for spilled concrete, proper ventilation and excessive leakage and for cracked / chipped porcelain.



Examine the manhole and cable grounding system to ensure its integrity. If cathodic protection has been installed in the manhole, it too should be evaluated. Corrective action should be taken as appropriate to maintain the integrity of these systems.

Aerial cables

Check supports for excessive wear or deterioration, check cables for wear at support points, inspect for mechanical damage from vibration. At dead-ends, check cable for worn insulation, sharp bends, or cracks.

Raceways

Check raceways for proper mechanical support of raceway and cables as well as check insulation for abrasion or cracks at support points. Examine raceway joints for clean and tight connections.

Bus duct

Bus duct joint covers should be removed to allow access for a thermographic survey of the energized bus under load. After de-energizing and grounding the bus duct, connections should be checked for proper tightness as well as evidence of overheating, corrosion, arcing, or other forms of deterioration. All loose or dirty connections should be cleaned and properly torqued. Be careful not to over-torqued the bolts. Consult the manufacturer for recommended maintenance practices and torque values. The tops of the bus duct enclosure should be inspected for evidence of water or other foreign matter that may contaminate the bust duct.

Testing

Suggested cable or bus tests include insulation resistance testing and polarization index testing. These tests should be recorded to track trends that may indicate a deterioration of the cable's insulation.

Transformers

Transformer data (such as, voltage, current, and temperature readings) should be recorded on a regular basis in order to determine operating conditions of the transformer. Peak, or redline, indicators should be recorded and reset. Readings taken on a weekly basis can provide important information about the loading of the transformer that is needed before additional loads can be added to the transformer.

Dry type transformers

After de-energizing and grounding the transformer, clean all coils, connections, and insulators of loose dust or dirt deposits with a vacuum cleaner. Examine the transformer for signs of overheating, deterioration, arcing, loose or broken parts, or other abnormal conditions. Ensure all connections are tightened according to manufacturer's specifications. Clean enclosure of any dust and dirt accumulations and ensure that vent openings are free from obstruction. If cooling fans are installed, examine for proper operations and lubricate as necessary.

Additional suggested testing includes an insulation resistance test, and a winding resistance test. These are non-destructive tests which can be performed to track the condition of the insulation over time. Detailed records should be maintained and analyzed to identify undesirable trends that may indicate the onset of an insulation failure.

Liquid-filled transformer

Insulating liquid samples should be taken annually and screen tested for dielectric breakdown, acidity, color, power factor, and interfacial tension. A Dissolved-Gas-in-Oil (DGA) test conducted by a qualified testing laboratory should be performed annually. The results should be trended to track conditions and schedule maintenance as necessary.

Examine the transformer tank and bushings for evidence of leakage. Inspect the bushings, insulators, and surge arrestors for broken or damaged parts, signs of overheating or arcing, or tracking. Clean all bushings, insulators, and surge arrestors of any dirt or dust accumulation. Tighten all conductor

connections in accordance with manufacturer's recommendations.

If applicable, perform a ground resistance test to ensure a value of 25 ohms or less.

Surge arrestors

Clean and inspect porcelain for signs of damage or deterioration. Repair or replace as necessary. Examine arrestor leads for damage and/or deterioration. Any gap-type silicone carbide arrestors should be replaced with modern metal oxide arrestors.

Other suggested tests are watts-loss and leakage current tests, insulation resistance tests, and grounding electrode circuit resistance tests. These should be conducted according to manufacturer's recommendations.

Protective relays

Inspection, maintenance and testing of protective relays should be done on an annual basis in order to ensure proper and reliable operation. All necessary precautions should be taken while working with protective devices to ensure personnel safety and to avoid any unplanned interruption of service. In particular, when working on control circuits, all current transformer (CT) secondaries should be shorted to ground and never left open-circuited in order to avoid serious injury to maintenance personnel.

Visual and mechanical inspection

Inspect relays for physical damage and deterioration. Inspect gaskets and covers for damage and /or excessive wear, and repair or replace as necessary. Examine and clean the relay and enclosure of foreign materials, such as dust, dirt, and moisture contamination. Examine the

condition of the spiral spring, disc clearances, contacts, and case shorting contacts (if present). Check mechanism for freedom of movement, proper travel and alignment, and tightness of counting hardware and plugs.

Electrical testing

Using an appropriate testing instrument, suitable for the relays being tested, conduct electrical testing of the relays in accordance with manufacturer's recommendations and IEEE testing standards. For over current relays, test the following functions of the relay at the established settings specified by the system engineer or manufacturer.

- Pickup contacts should close when a current equal to the relay tap setting is applied to the induction coil. Adjust the spring as needed to allow for proper operation.
- Timing tests should be performed corresponding to two (2) or more points on the relay's time-current curves. One of the tests should be done at the specified time dial setting.
- Instantaneous pickup test should be performed for the specified instantaneous setting, if applicable.
- Seal-in units should be tested to ensure that the contacts hold closed with the minimum specified current applied.
- Relay target should indicate when the relay has operated. If possible, the relays should be tested to ensure that operation of the relay will in fact cause a tripping action of the respective circuit breaker.

Relays that do not test satisfactorily or are found to be defective should be replaced immediately to maintain the integrity of the protection systems.

UPS systems

This section provides general recommended maintenance guidelines for Uninterruptible Power Supply (UPS) systems. Since there is a wide variety of systems and equipment available, the manufacturer's instructions and recommendations should be consulted for more complete and detailed maintenance requirements.

UPS systems are categorized in two basic ways: static and rotary. For the purposes of this standard, only static systems will be addressed.

When performing any maintenance and/or testing of UPS systems, follow all recommended safety procedures as indicated by the manufacturer and required by Canadian Health & Safety Legislation and/or WHMIS. Only fully trained and qualified persons with proper test equipment should perform UPS maintenance.

Clean interior and exterior of cabinets and enclosures, ensuring that any areas of corrosion and/or deterioration are repaired as necessary. Clean all vent and air circulation openings and ensure freedom from obstructions. If installed, clean cooling fan blades and motor housings. Ensure that motor bearings are properly lubricated and that fan blades are properly secured to drive shafts. Examine for signs of moisture contamination and correct if necessary.

Clean and examine all electrical connections for signs of corrosion or deterioration, repair or replace as necessary. Ensure all connections are tightened according to manufacturer's specifications. As applicable, clean and test all breakers, disconnects, and relays as prescribed elsewhere in these standards and as specified by the manufacturer. Check all system alarms and indicating lights for proper operation.

Check inverters for fluid leaks from wave-forming capacitors. Check capacitors for signs of bulging or discoloration. Examine transformers and heat sinks for signs of overheating. Maintain batteries as prescribed in section 3.7 of this standard and as specified by the manufacturer.

Motors

Why do motors fail?

Virtually every kind of facility or business relies on electric motors to drive something. Many large manufacturing plants have thousands of motors and their "critical" motors number in the hundreds. Unfortunately, motors are so reliable and efficient, that many receive little attention, until they fail.



Electric motor failures can be put into two major categories: mechanical breakdowns and electrical breakdowns. Causes for mechanical breakdowns include loss of lubrication, worn-out bearings, coupling misalignment, rotor unbalance, etc. Periodic vibration monitoring, and lubrication analysis can often help to detect these faults early enough to avoid failure.

Most electrical breakdowns occur as a result of the motor's environment – too dirty or wet, too warm, or too much movement.

Contamination – Failures often occur when elements in the environment such as moisture, abrasive or conducting dust, or chemicals react with the insulation system to lower the resistance between phases, or phase to ground. Contamination can be high humidity, oil leaking from the bearings, aggressive chemicals or many other common occurrences.

Heat – Motor windings are designed by the manufacturer to operate at or below a certain temperature. If the winding is operated hotter than design, thermal aging of the insulation occurs at a more rapid rate and machine life expectancy is reduced. A general rule is that for each 10°C over rated temperature that the motor is operated, the insulation life is cut in half.

Movement – The major cause of electrical failures is movement of the coils during start-up and operation. This includes motion between coils or conductors and the core iron, between conductors within the coils themselves, and between conductors and their supporting structure or bracing. The mechanical stresses caused by starting under heavy load, as well as the natural magnetic stresses cause a flexing of the coils, forcing them to move outward and sideways. This movement usually results in a short to ground, in the end turns, where the coil leaves the slot of the stator iron. Shorts also occur between strands of wire in random wound motors and between turns within a coil in form-wound motors.

A turn-to-turn short circuit creates a decrease in the equivalent number of winding turns, which increases the stator winding current, and thus

increases the heat loss. The increased heating accelerates the thermal degradation of the surrounding insulation, which results in additional shorted turns and further increases in temperature.

Maintenance inspections

A well-balanced maintenance program for motors is based on diagnostic testing and visual inspection, performed by qualified, knowledgeable personnel. There are no test methods available which can replace the need for a good visual inspection. A visual inspection program should concentrate on those areas most prone to damage or degradation. Observation of the external condition of the motor should include:

- Evidence of damage caused by dirt, loose parts, or foreign objects.
- Verification that air inlets are not blocked.
- Evidence of moisture and/or dirt buildup.
- Unusual noises, leaking oil seals, or high vibration.
- Oil level gages (if present) should be checked.
- Evidence of oil leakage at the bearings.
- Degradation of foundation, bed plates, anchor bolts.

Inspection of the end winding conditions with a borescope or directly, may reveal conditions of winding ties and evidence of loose coils, such as dusting or greasing at the coil support points. Not all motors need annual maintenance, but the service life will be increased if a prudent annual inspection program is followed.

Electrical test methods

Even with today's advanced technology, there is still no single electrical test that can positively determine the remaining useful life of a motor's insulation. At best, we can assess the insulation integrity from the knowledge of the insulation characteristics, the stresses experienced by the machine, experience with similar machines, a physical examination, and a trend of diagnostic tests over time.

There are a number of electrical test methods which are widely used in industry today. Some of the best have only become practical in the field within the last few years. Each of the following methods works well for its intended use.

Two of the older, traditional methods that are still commonly used are the insulation resistance and the high potential (hi-pot) test. Both of these tests concentrate on the integrity of the phase to ground insulation – they cannot check the condition of coil-to-coil, or phase-to-phase insulation.

Insulation Resistance Test: The frame of the motor is grounded, and a DC voltage (typically 500 or 1000 volts for a 480v motor) is applied to the windings. If the insulation is in good condition, the resistance reading may be hundreds of megohms. The IEEE minimum acceptable standard is 1 megohm plus 1 megohm for each 1000v of motor rating. (A minimum acceptable reading for a 4160v motor is 5.16 megohms). As a minimum, HSB recommends an insulation resistance test on a three year basis; the test results should be recorded and trended to identify potential insulation degradation over time.

The High-Potential (hi-pot) test is an industry accepted, pass/fail test that is ideally suited for new or recently rewound motors. An AC or DC voltage is applied to the windings at twice the operating voltage plus 1000v. (A 4160v motor is tested at 9000 volts!) Both the AC and DC "hi-pot" tests are considered destructive tests, because marginal equipment can fail prematurely while undergoing this test. Therefore, hi-pot testing is **not recommended** by HSB.

Motor Current Signature Analysis is a relatively new technique that can help detect broken rotor bars, cracked rotor end ring, loose rotor joints, bent shafts, and worn bearings. This inexpensive test measures side-band frequency spectra from the line current while the motor is running. Sophisticated software then process the raw signal and analyzes the signature in both time and frequency domains.

Surge Comparison Testing uses a charged capacitor to pulse a voltage into two windings of a motor simultaneously. The voltage is set low to begin and raised slowly while the operator watches the wave forms on an oscilloscope. The voltage pulse is eventually raised to twice the operating voltage, plus 1000 volts. Since the windings are supposed to be identical, the wave forms should be identical – a difference in wave forms indicates a problem. A skilled operator can determine the exact type of fault (turn to turn, phase to phase etc.) by studying the wave form patterns. This test can also be considered a potentially destructive test, because marginal motors can fail under test, if the test is not done properly.

Infrared inspection

An infrared, or thermographic, inspection should be performed at least once every three years on all switchgear, distribution panels, cable and bus connections, motor control centers and starters, and other critical equipment. Infrared inspections are



extremely beneficial in reducing electrical failures by identifying potentially dangerous conditions; such as loose or dirty connections, overloaded or imbalanced circuits, or improperly installed equipment. By measuring the heat imbalance relative to the environment and to surrounding equipment, abnormal or adverse conditions can be uncovered that if left unattended would worsen to the point of failure.

Infrared (IR) surveys are very helpful in planning the work scope of an upcoming scheduled outage. Prior to the planned maintenance, an IR survey should be conducted to help identify areas that need specific and immediate attention. Resources can then be allocated to address these specific problems during the deenergized period.

Infrared surveys are done on energized equipment and should be conducted during peak demand periods if possible. This will reveal the most serious problems and those that would otherwise go undetected. At a minimum, the loading should be at least 40% of the rated load of the equipment being inspected.

Effective infrared surveys require specialized equipment and should be performed only by qualified technicians. Experience and training is required to accurately identify problem conditions and possible causes so that specific recommendations can be made to correct the situation. It is imperative that these recommendations be implemented in a timely manner to benefit from an infrared inspection. Knowing a problem exists does not help avoid an electrical failure unless corrective actions are employed.



Record keeping

The electrical preventive maintenance program should be well-documented as to scope and frequency of maintenance. Record all routine maintenance activities and the results

of routine testing for trending purposes. Document all repair and/or replacement of electrical components. When changes are made to the electrical distribution system, update all applicable drawings and maintenance schedules to reflect the changes. Ensure that spare parts inventories are updated for any new equipment added based on the manufacturer's recommendations.

Standards

Any electrical preventive maintenance program should be performed in accordance with accepted industry standards and work / safety practices. This includes, but is not limited to, the latest releases of the following:

- Canadian Electrical Code Part I – Electrical Installations
- Canadian Electrical Code Part II – Consumer and Commercial Products
- Canadian Electrical Code Part II – General Requirements
- Canadian Electrical Code Part II – Industrial Products
- Canadian Electrical Code Part II – Wiring Products
- Canadian Electrical Code Part III
- Electricity Distribution and Transmission
- Electrical Engineering Standards
- Electromagnetic Compatibility (EMC)
- Harmonized Electrical Standards

Note: Upgrades or expansion of electrical systems should be designed by a competent professional engineer and installed by qualified electricians.

HSB Canada

390 Bay Street, Suite 2000
Toronto, ON M5H 2Y2
Tel.: (416) 363-5491

hsb.ca

These recommendations are general guidelines and are not intended to be exhaustive or complete, nor are they designed to replace information or instructions from the manufacturer of your equipment.
© 2020 The Boiler Inspection and Insurance Company of Canada. All rights reserved.

