

HEATING BOILER LOG

(Post near boiler and initial when tested)

MANUFACTURER										BOILER NUMBER					YEAR								
MONTH	SAFETY VALVE TESTED (Quarterly)		LOG THIS INFORMATION WEEKLY	GAGE GLASS DRAINED					LOW-WATER FUEL CUTOFF TESTED					PUMP SYSTEM CHECKED					BURNER OPERATION CHECKED				
	DATE PERFORMED			WEEK					WEEK					WEEK					WEEK				
	1	2		3	4	5	1	2	3	4	5	1	2	3	4	5	1	2	3	4	5		
SEP																							
OCT																							
NOV																							
DEC																							
JAN																							
FEB																							
MAR																							
APR																							
MAY																							
JUN																							
JUL																							
AUG																							

(If you have any questions regarding your equipment or need to schedule an inspection, call 1-800-333-4677.)

© 2017 All rights reserved.
This log is intended to complement the equipment manufacturers' recommendations - not replace them. If you have doubts about any particular testing or maintenance procedure, contact the manufacturer or your equipment service representative.

SEND REQUESTS FOR ADDITIONAL TAGS TO:

The Hartford Steam Boiler Inspection and Insurance Company
Attn: Inspection Services
Hartford Steam Boiler
PO Box 61509
King of Prussia, PA 19406
or by email: NSCINSP_hotline@hsb.com

or scan this code



IMPORTANT

TEST INSTRUCTIONS

- A. SAFETY / RELIEF VALVES** – Test quarterly while the boiler is in operation. Lift the try-lever to full open position, then release lever to allow valve to snap closed. Pressure test annually by a qualified service personnel to verify the valve opens at set pressure.
- B. WATER COLUMN OR GAGE GLASS** (Steam Boilers) – For low-pressure steam boilers, flush water column, and gage glass weekly. Open drain valve quickly to void small quantity of water.* Water level should return quickly to normal operating level when valve is closed.
- C. PRESSURE/TEMPERATURE GAGES** – Verify consistent system pressure and temperature daily.
- D. LOW-WATER FUEL CUTOFF (LWCO)** – For steam boilers, test weekly and for hot-water boilers test monthly. For float-type LWCO, drain the float chamber while burner is running.* For probe-type, drain the water column or use the test button on the device. These tests should interrupt the circuit and stop burner. For steam boilers, conduct a slow drain test annually by qualified service personnel.
- E. PUMP AND SYSTEM** – For all boilers, check daily, pump for proper operation, leaky packing. Examine check valves, makeup float valves, expansion or condensate tank. Check for leaks in other parts of system.
- F. BURNER OPERATION** – If burner starts with a puff or operates roughly, call your service personnel immediately.
* All Discharges must be piped to a safe place.

SERVICING

- A. LOW-WATER FUEL CUTOFF (LWCO)** – For all steam boilers, the low-water fuel cutoff should be dismantled for a complete overhaul by qualified service personnel at least annually. The internal and external mechanisms, including linkage contacts, mercury

bulbs, floats, and wiring should be carefully checked for defects. Probe-type LWCOs should also be examined for cracking and deposits. See manufacturer's instructions.

Record and initial service dates below.

Initial:
Date:

- B. OIL OR GAS BURNERS AND CONTROLS** – Oil and gas burners and all operating and safety controls should be thoroughly checked at least annually by a competent service organization. **CAUTION:** If any single control is replaced, all controls should be retested to ensure they still function properly. See manufacturer's instructions.

Record and initial service dates below.

Initial:
Date:

- C. Temperature and pressure indicators and gages** – Calibrate all gages and indicators annually. See manufacturer's instructions.

Record and initial service dates below.

Initial:
Date:

BOILER SAFETY RULES

- NEVER** take it for granted that the boiler safety devices are in working order – **TEST THEM.**
- ALWAYS** check the boiler periodically. **THE BEST CONTROL CAN FAIL.**
- ALWAYS** maintain the water at the proper level in an operating boiler.
- ALWAYS** familiarize yourself with proper operation of the boiler. An experienced operator can often avoid trouble before it starts.